

DECLARATION OF PERFORMANCE NO. 25022016 VARIANT N III WRAP



Date: 18.04.2017
Rev. 01
Page 1 of 2

Product	FLAMRO Variant N III wrap
1. Unique identification code of the product-type	RA-16-0056
2. Intended use	Pipe sealing
3. Manufacturer	FLAMRO Brandschutz-Systeme GmbH Am Sportplatz 2 56291 Leiningen
4. Authorised representative	not relevant
5. System(s) of AVCP	System 1
6a) Harmonised standard	not relevant
6b) European Assessment Document	ETAG No. 026 Part 2, August 2011
European Technical Assessment	ETA-16/0056
Technical Assessment Body	ETA-Danmark A/S, DK-2150 Nordhavn
Notified body/ ies	Materialprüfanstalt für das Bauwesen Braunschweig, No. 0761
7. Declared performances	

Essential characteristics	Performance	Harmonised technical specification
Fire resistance as a pipe sealing for combustible or non-combustible pipes made of PVC, PE, PP, eg *) with the fire protection collar type Variant N III wrap in flexible and rigid walls, thickness at least 100 mm or rigid floors, thickness at least 150 mm. *)	Max. EI 120 - U/U or Max. EI 240 - U/C	
Durability and serviceability	use category type Y ₂ / X	
Air permeability	NPD	ETA-16/0056
Water permeability	NPD	
Release of dangerous substances	none	
Mechanical resistance and stability	NPD	
Resistance to impact/ movement	NPD	

DECLARATION OF PERFORMANCE NO. 25022016 VARIANT N III WRAP



Date: 18.04.2017
Rev. 01
Page 2 of 2

Adhesion	NPD	
Airborne sound insulation	NPD	
Thermal properties	NPD	
Water vapour permeability	NPD	ETA-16/0056
Components - reaction to fire:	Class acc. to EN 13501-1	
FLAMRO Variant N III wrap	E	
FLAMRO BML	E	
FLAMRO BMS	E	
FLAMRO BMK	E	
Mineral wool slab, density 150 kg/m ³	A1	

*) according to ETA-16/0056

8. Appropriate Technical Documentation /
Specific Technical Documentation not relevant

Online-copy of Declaration of Performance www.flamro.com

The performance of the product identified above is in conformity with the set of declared performance/s. This declaration of performance is issued, in accordance with Regulation (EU) No. 305/2011, under the sole responsibility of the manufacturer identified above.

Signed for and on behalf of the manufacturer by:

Dr. Hemp, Head of R & D, FLAMRO Brandschutz-Systeme GmbH