



Declaration of Performance
N° 0128-PYRO-SAFE-CT
PYRO-SAFE CT/ CT ML Cable Tube

Date: 29.01.2016
Rev. 04
Page 1 of 1

Unique identification code of the product type
PYRO-SAFE CT/ CT ML Cable Tube

Intended use:

Product for cable penetration seal

The cable penetration seal is used for closing openings in fire-resistant walls or floors, through which cables were passed. It is to maintain the fire resistance of the wall or floor in the region of the penetration.

Producer

svt Brandschutz Vertriebsgesellschaft mbH International
Gluesinger Strasse 86
D - 21217 Seevetal

System for assessing and verifying constancy of performance
System 1

European Assessment Document
ETAG 026-2:2008-01-01

Table with 2 columns: European Technical Approval/Assessment, EC certificate of conformity. Rows include ETA-13/0821 dated 28.06.2013 and ETA-16/0016 dated 18.01.2016.

Technical Assessment Body

Deutsches Institut für Bautechnik (DIBt), Berlin

The notified body

Materialprüfanstalt für das Bauwesen Braunschweig, code number 0761

Declared performance

Table with 3 columns: Essential characteristics, Performance, Harmonised technical specifications. Rows include Reaction to fire, Fire resistance, Emission of dangerous substances, and Durability and serviceability.

The performance of the product identified above is in conformity with the set of declared performances. This declaration of performance is issued, in accordance with Regulation (EU) No. 305/2011, under the sole responsibility of the manufacturer identified above

DoP online available at www.svt.de.

Signed for and on behalf of the manufacturer by:

Handwritten signature of Christian Meyer-Korte

i.V. Christian Meyer-Korte
Head of Product Management

Handwritten signature of Andree Schober

i.V. Andree Schober
Head of chemical department