

MPA Braunschweig, Beethovenstr. 52, 38106 Braunschweig, Germany

Certificate of constancy of performance

0761 – CPR – 0460

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Product Regulation or CPR), this certificate applies to the construction product

**cable penetration seals with the trade names
'PYRO-SAFE CT Cable Tube' and 'PYRO-SAFE CT ML Cable Tube'**

produced by or for

**svt Brandschutz
Vertriebsgesellschaft mbH International
Glüsinger Straße 86
21217 Seevetal
Germany**

in the manufacturing plant

Seevetal (Germany).

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in the European Technical Assessment

ETA-16/0016 of 18-01-2016

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

constancy of performance of the construction product.

The construction products 'PYRO-SAFE CT Cable Tube' und 'PYRO-SAFE CT ML Cable Tube' are used as components for cable penetration seals. They shut openings in fire-resistant walls and ceilings and safeguard the fire-resistance of the wall or the ceiling where they are penetrated.

This certificate has first been issued on 03-02-2016. It will remain valid till 02-02-2021, as neither the harmonised specification, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the product certification body.

Braunschweig, 03-02-2016

Z-3/1222/13



.....
Dr.-Ing. W. Hinrichs
Head of certification